

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7125-0785:125 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-8707

DESIGN: Models **ET-1070, ET-1071, ET-1080, ET-1081, ET-1090, ET-1091, E-7025, E-7070, E-9025**
and **E-9070** speaker/strobes with the following suffixes:

LS or **SL*** (15cd), **LSM** or **SLM*** (15cd/75cd), **MS** or **MSP** (30cd), **IS** (75cd), **HSW**
or **HSPW** or **SHPW*** (110cd).

12 (10-15.6 VDC) or **24** (20-31 VDC)

No Suffix (60 flashes/min) or **L** (20 flashes/min)

Units may follow by suffixes to designate orientation, lettering and plate color. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models using LSM, SLM* HSW or HSPW strobes are for wall mount only. Other units are suitable for wall or ceiling mount.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible/visual signaling devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. *Model with suffix SL, SLM or SHPW employs a synchronized strobe and must be used with Model SCM-24 sync control module.

*If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 12-08-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 11, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager